

## Response from Fire and Rescue Service

Dawn,

In response to your email and to update you on what we have done so far.

Firstly, we received a water scheme from Albion Water late 2013 and we forwarded our requests in January 2014.

We did not send this to CDC, so I can only assume that the Developer or Albion Water contacted CDC.

Would it be possible for you to send me the drawing you have received? I can then check if their locations match with ours.

Regarding what we have found and the work we have carried out.

### **Main Development**

- We requested 9 hydrants.
- We have located 8 of these.
- The one we cannot find should be in Barns Wallis Way.
- Of the 8 located, all but one have FH covers. This particular hydrant is also in a slightly different position than we requested, but will be OK in this position.
- All these hydrants are fully operable and available for our use, although nearly all these need further work to bring them up to our specification for actual adoption.
- All have had the covers painted yellow and all have indicator plates.
- We identified that there were several old hydrants and markers that need removing.

### **Phase 6 (Smith Barry Road)**

- We requested 2 hydrants.
- We have located 1 of these.
- The one we cannot locate is near Plot No 30.
- We have managed to locate a washout though which we mark as a hydrant in the meantime. This is near Plot 46.
- Both hydrants are fully operable, have FH covers which have been painted yellow and have indicator plates.

### **Next Actions**

- Contact Albion Water regarding the missing hydrants and rectification work including removal of old abandoned hydrants and markers.
- Contact Cotswold District Council.
- Make hydrants identified as operable 'Live' on our Data System.
- Contact local stations to keep them updated.
- Keep the Parish Council updated on any further developments.

We are happy that there is sufficient operable hydrants.

I will give Brian Hanks a call to explain the current situation. In the meantime if you require any further information please don't hesitate to give me a call.

Regards

Kevin

**Hydrant and Water Manager  
Hydrant and Water Team**

Gloucestershire Fire & Rescue Service

Tri Service Centre, Waterwells Drive, Quedgeley, Gloucester, GL2 2AX

Tel: 01452 888749

Mobile: 07768261397

[www.glosfire.gov.uk](http://www.glosfire.gov.uk)



Gloucestershire  
**Fire and Rescue Service**

Working together for a safer Gloucestershire

**63% less fires now than 10 years ago and 20 less casualties every year**  
**53% fewer road collisions than 10 years ago and 118 less casualties each year**